

Small scale combustion of pelletized low quality wood – Impact of the additives on ash characteristics and emission behaviour

Thomas Zeng



Side Workshop “REDUCING WASTE WOOD ASH RELATED OPERATIONAL PROBLEMS IN USING ADDITIVES”
WORLD SUSTAINABLE ENERGY DAYS in WELS, Austria on 28th of February 2019

Objective



- To determine the influence of recycled gypsum and halloysite on reducing ash related operational problems in combustion of wood waste fuels.
 - ✓ Impact of the used additives on gaseous and particulate matter emission behaviour
 - ✓ Impact of the used additives on bottom ash slagging and emission behaviour

Raw materials



- Residues from wood chip board production, i.e. A II used wood (**WCB**)
 - ✓ particle size: about 60% < 3.15 mm
 - ✓ bulk density: 337 kg/m³
- Wood logging residues (**WLR**)
 - ✓ Wood chip quality: less than class B (ISO 17225-4)
 - ✓ M10
- Gypsum, **G** ($\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$)
 - ✓ origin: Gips Recycling Nederland BV
 - ✓ bulk density: 700 kg/m³
- Hallosite, **H** ($\text{Al}_2(\text{Si}_2\text{O}_7) \cdot 2\text{H}_2\text{O}$)
 - ✓ origin: PTH INTERMARK, poland
 - ✓ bulk density: 1080 kg/m³

Raw materials – additive amounts

- Calculation of Gypsum addition

$$S_{\text{add}} = (F_{\text{stoich}} ((K + Na)/2 + Zn + Pb) - 0.64 S_{\text{fuel}}) / 0.64$$

- Calculation of Halloysite addition

$$\text{Alk}_{\text{cap}} = \text{Al}_{\text{add}} - (K_{\text{add}} + Na_{\text{add}} + 2(Ca_{\text{add}} + Mg_{\text{add}}))$$

$$\text{Amount}_{\text{add}} = (K_{\text{fuel}} + Na_{\text{fuel}}) / \text{Alk}_{\text{cap}}$$



- WLR ($F_{\text{stoich}}=1.5$)

- ✓ Gypsum: 13.4 kg Add / t dry fuel
 - ✓ Halloysite: 31.7 kg Add / t dry fuel

- WCB ($F_{\text{stoich}}=1.5$)

- ✓ Gypsum: 4.3 kg Add / t dry fuel
 - ✓ Halloysite: 10.6 kg Add / t dry fuel

Pelleting tests



Netzsch ammer mill
type CONDUX-Hammermühle
(CHM 230/200-N3):
- 4 kW
- 3000 U/min



Conditioning
type Chargenmixer
(AT-ENGINEERING, Slovakia):
- capacity 0,3 m³





Salmatec pelleting plant
type Maxima 360-40 mini:
- 30 kW
- 3-Koller-System
- integrated monitoring of
temperature and energy
consumption



Pellet cooling device
own design (DBFZ):
- heating 18 kW
- ventilation 3 kW
- capacity ca. 1 m³

Pelleting tests

Extraneous material



Wearing of hammer

Fuel	Production related amount of fines [wt%]	Pellet mass flow [kg/h]	Specific energy consumption [kWh/kg]
WLR	25.9	70.5	0.30
WLR+G	15.8	79.4	0.27
WLR+H	11.7	127.5	0.19
WCB	16.4	104.7	0.20
WCB+G	11.3	90.9	0.22
WCB+H	15.1	87.9	0.17

Combustion tests


- Analysis of biomass fuels (major and minor components, physical-mechanical properties, proximate analysis)
- Small-scale heating appliance with moving step grate (nominal heat capacity 30 kW)
- Measurement of gaseous emissions CO, NO_x, SO₂, HCl (Ansyo / FTIR Gasmet CR)
- Measurement of total particulate matter emissions, TPM (VDI 2066-1)
- Sampling and analysis of bottom ash and total particulate matter for analysis (ICP, XRD)




Additive and fuel pellet analysis

Parameter	Unit	WLR	WLR+G	WLR+H	WCB	WCB+G	WCB+H	Clean wood
Bulk density	kg/m ³	661	671	648	569	614	600	633
Mechanical durability	wt%	95.69	94.2	93.9	94.3	96.1	95.2	99.0
Ash content	wt% dry	3.10	4.53	6.15	1.49	1.79	2.26	0.33
Nitrogen	wt% dry	0.50	0.47	0.45	4.33	4.37	4.15	0.21
Chlorine	wt% dry	0.012	0.011	0.012	0.026	0.026	0.028	0.01
Sulfur	wt% dry	0.045	0.200	0.048	0.027	0.093	0.028	0.004
Potassium	mg/kg dry	2310	2330	2400	453	390	295	497
(Si+P+K)/(Ca+Mg)	mol/mol	1.82	1.53	3.43	0.64	0.45	1.18	0.8
Si/K	mol/mol	3.13	4.01	7.25	2.88	309	10.10	0.38
2S/Cl	mol/mol	8.29	40.21	8.85	2.30	7.91	2.21	0.80
K/Cl	mol/mol	17.46	19.21	18.14	1.58	1.36	0.96	4.1


Emissions





Emissions



Analysis of total particulate matter



Bottom ash analysis



Conclusions

Halloysite

- Although the addition of H provides advantages for pelleting and reduction of particulate matter in the flue gas, the increase of ash content and the risk of bottom ash slagging seem to provide serious challenges for waste wood combustion in small scale boilers.

Gypsum

- Although high SO₂ emissions were observed, the reduction potential of Cl containing particles is promising.
- Good prediction of Gypsum amounts is required to minimise potential SO₂ emissions.

Smart Bioenergy – Innovationen für eine nachhaltige Zukunft

Ansprechpartner

Prof. Dr. mont. Michael Nelles
Daniel Mayer
Prof. Dr.-Ing. Daniela Thrän
Dr.-Ing. Jan Liebetrau
Dr.-Ing. Volker Lenz
Dr.-Ing. Franziska Müller-Langer
Dr.rer.nat. Ingo Hartmann

**DBFZ Deutsches
Biomasseforschungszentrum
gemeinnützige GmbH**

Torgauer Straße 116
D-04347 Leipzig
Tel.: +49 (0)341 2434-112
E-Mail: info@dbfz.de
www.dbfz.de